

## REGIONAL WATER TESTING LAB, SAS NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab  
mdlsasnagar@gmail.com

### TEST REPORT

Name & Address of Customer : <b>Mata Sahib Kaur Public School</b> <b>Mata Sahib Kaur Public School, village - Sawara,</b> <b>Kharar, SAS Nagar</b>		Customer Reference No.	No : Letter No MSKPS/3393/P/2026 Dated : 04/05/2026	
		Sample Submitted by	Hardeep Singh	
		Date of Sample Receipt	04/05/2026	
		Analysis Starting Date	04/05/2026	
		Analysis completion Date	08/05/2026	
Discipline : <b>Bacteriological Testing</b>		Group: <b>Water</b>		
ULR No.:		Sample Type :	Water	
Test Report No.:	RWTLAS/2627/00120	Date of Issue :	12/05/2026	
Registration no.:	RWTLAS/REG2627/00439	Condition of Sample :	Sealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / NA	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Mata Sahib Kaur Public School, Sawara, SAS Nagar (RO water) / NA	
Village :	Not Mentioned	Habitation :	Not Mentioned	
Block:	Not Mentioned	District :	SAS Nagar	
Latitude :	30.687255	Longitude:	76.635186	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	Absent	Shall not be detectable in any 100 ml sample	No relaxation	CFU/100 ml.	IS 15185 Membrane Filtration Method
2	E-Coli	Absent	Shall not be detectable in any 100 ml sample	No relaxation	CFU/100 ml.	IS 15185 Membrane Filtration Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

*Manik Kataria*

**Mr. Manik Kataria**  
**Sr. Chemist**  
**Authorized Signatory**  
**For, Regional Water Testing Lab**  
**SAS Nagar**

----- End of the Test Report -----

*S.S. Singh*  
Principal  
Mata Sahib Kaur Public School  
Swara, Tehsil Kharar, Mohali

*[Signature]*  
Manager  
Mata Sahib Kaur Public School  
Swara (Mohali)